



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

Sample ID JH2309073
 Federal Water Supply Code NY5503394 Supply Code 2302
 Water Supply Town Woodstock Water Department DOH Ulster Co Robt
 Address 45 Comeau Drive Woodstock NY 12498
 Sample Location Pumphouse #1
 Date Collected 10/17/2023 Time Collected 8:20 AM
 Sample Collector LA
 Date Printed 11/17/2023

Lab ID 10861 Date Analyzed 11/16/23

EPA 533 Perfluorinated and Polyfluorinated Alkyl Compounds

<u>PARAMETER</u>	<u>CONCENTRATION</u> ng/L	<u>RL</u>	<u>MDL</u>	<u>PARAMETER</u>	<u>CONCENTRATION</u> ng/L	<u>RL</u>	<u>MDL</u>	<u>MCL</u>
11CI-PF3OUdS	<1.91	1.91		PFBA	<1.91	1.91		
ADONA	<1.91	1.91		PFDA	<1.91	1.91		
4:2 FTS	<1.91	1.91		PFDoA	<1.91	1.91		
6:2 FTS	<1.91	1.91		PFHpS	<1.91	1.91		
8:2 FTS	<1.91	1.91		PFHpA	<1.91	1.91		
9CI-PF3ONS	<1.91	1.91		PFHxS	<1.91	1.91		
HFPO-DA	<1.91	1.91		PFHxA	<1.91	1.91		
NFDHA	<1.91	1.91		PFNA	<1.91	1.91		
PFEESA	<1.91	1.91		PFOS	3.48	1.91		10 ng/L
PFMPA	<1.91	1.91		PFOA	<1.91	1.91		10 ng/L
PFMBA	<1.91	1.91		PFPeS	<1.91	1.91		
PFBS	<1.91	1.91		PFPeA	<1.91	1.91		
				PFUnA	<1.91	1.91		

<u>PARAMETER</u>	<u>CONCENTRATION</u> ug/L	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	Date Analyzed	Lab #
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	11/2/23	11549
Surrogate Recovery %						
1,4-Dioxane-d8	93.4					

Legend: RL = Report Limit Comments MDL not reported
 MCL = Maximum Contamination Level
 ND - Not Detected
 MDL - Method Detection Limit
 J - Result is less than the RL but greater than or equal to the MDL and concentration is an approximate value.



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

Sample ID JH2309074
 Federal Water Supply Code NY5503394 Supply Code 2302
 Water Supply Town Woodstock Water Department DOH Ulster Co Robt
 Address 45 Comeau Drive Woodstock NY 12498
 Sample Location Pumphouse #2
 Date Collected 10/17/2023 Time Collected 8:30 AM
 Sample Collector LA
 Date Printed 11/17/2023

Lab ID 10861 Date Analyzed 11/16/23

EPA 533 Perfluorinated and Polyfluorinated Alkyl Compounds

<u>PARAMETER</u>	<u>CONCENTRATION</u> ng/L	<u>RL</u>	<u>MDL</u>	<u>PARAMETER</u>	<u>CONCENTRATION</u> ng/L	<u>RL</u>	<u>MDL</u>	<u>MCL</u>
11CI-PF3OUdS	<1.79	1.79		PFBA	<1.79	1.79		
ADONA	<1.79	1.79		PFDA	<1.79	1.79		
4:2 FTS	<1.79	1.79		PFDoA	<1.79	1.79		
6:2 FTS	<1.79	1.79		PFHpS	<1.79	1.79		
8:2 FTS	<1.79	1.79		PFHpA	<1.79	1.79		
9CI-PF3ONS	<1.79	1.79		PFHxS	<1.79	1.79		
HFPO-DA	<1.79	1.79		PFHxA	<1.79	1.79		
NFDHA	<1.79	1.79		PFNA	<1.79	1.79		
PFEESA	<1.79	1.79		PFOS	<1.79	1.79		10 ng/L
PFMPA	<1.79	1.79		PFOA	<1.79	1.79		10 ng/L
PFMBA	<1.79	1.79		PFPeS	<1.79	1.79		
PFBS	<1.79	1.79		PFPeA	<1.79	1.79		
				PFUnA	<1.79	1.79		

<u>PARAMETER</u>	<u>CONCENTRATION</u> ug/L	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	Date Analyzed	Lab #
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	11/2/23	11549
Surrogate Recovery %						
1,4-Dioxane-d8	91.6					

Legend: RL = Report Limit Comments MDL not reported
 MCL = Maximum Contamination Level
 ND - Not Detected
 MDL - Method Detection Limit
 J - Result is less than the RL but greater than or equal to the MDL and concentration is an approximate value.