

ENVIRONMENTAL LABWORKS, INC.

March 31, 2025

Mr. Larry Allen
Woodstock Wastewater Facility
45 Comeau Drive
Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on a water sample from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 03/19/25.

Date/Time Collected: 03/19/25 9:00am
Collected By: Woodstock
Project ID: 03192532
Secondary ID: WD250894
PWS ID: 5503394

Location: Pumphouse #2 Well #1
Sample ID: 03192532-2

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533(Y2)				
ADONA	ND ng/L	1.97		03/27/25
9Cl-PF3ONS	ND ng/L	1.97		03/27/25
11Cl-PF3OUdS	ND ng/L	1.97		03/27/25
HFPO-DA(Gen-X)	ND ng/L	1.97		03/27/25
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.97		03/27/25
Perfluorodecanoic acid(PFDA)	ND ng/L	1.97	10	03/27/25
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.97		03/27/25
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.97	10	03/27/25
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.97	10	03/27/25
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.97		03/27/25
Perfluorononanoic acid (PFNA)	ND ng/L	1.97	10	03/27/25
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.97	10	03/27/25
Perfluorooctanoic acid(PFOA)	ND ng/L	1.97	10	03/27/25
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.97		03/27/25
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.97		03/27/25
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.97		03/27/25
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.97		03/27/25
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.97		03/27/25
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.97		03/27/25
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.97		03/27/25
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.97		03/27/25
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.97		03/27/25
Perfluoro-4-oxapentanoic acid(PFMBA)	ND ng/L	1.97		03/27/25
Perfluoro-3,6-dioxahexanoic acid(NFDHA)	ND ng/L	1.97		03/27/25
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.97		03/27/25
PFAS EPA 533 Hazard Index (calculation)	0.00		1	03/27/25

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 03192532

Location: Field Blank
Sample ID: 03192532-2 Blk


PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533(Y2)				
ADONA	ND ng/L	1.74		03/27/25
9Cl-PF3ONS	ND ng/L	1.74		03/27/25
11Cl-PF3OUdS	ND ng/L	1.74		03/27/25
HFPO-DA(Gen-X)	ND ng/L	1.74		03/27/25
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.74		03/27/25
Perfluorodecanoic acid(PFDA)	ND ng/L	1.74	10	03/27/25
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.74	10	03/27/25
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.74	10	03/27/25
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.74	10	03/27/25
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.74		03/27/25
Perfluorononanoic acid (PFNA)	ND ng/L	1.74	10	03/27/25
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.74	10	03/27/25
Perfluorooctanoic acid(PFOA)	ND ng/L	1.74	10	03/27/25
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.74		03/27/25
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.74		03/27/25
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.74		03/27/25
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.74		03/27/25
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.74		03/27/25
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.74		03/27/25
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.74		03/27/25
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.74		03/27/25
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.74		03/27/25
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.74		03/27/25
Perfluoro-3,6-dioxahexanoic acid(NFDHA)	ND ng/L	1.74		03/27/25
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.74		03/27/25
PFAS EPA 533 Hazard Index (calculation)	0.00		1	03/27/25

Definitions:

MCL - Maximum Contaminant Level
ND - Not Detected
RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12058(Y2). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Laboratory Director