

ENVIRONMENTAL LABWORKS, INC.

March 19, 2026

Mr. Larry Allen
 Woodstock Wastewater Facility
 45 Comeau Drive
 Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on water samples from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 03/04/26.

Date/Time Collected: 03/04/26 8:10-8:40am
 Collected By: Woodstock
 Project ID: 03042660
 Secondary ID: TW260840-41
 PWS ID: 5503394

Location: Pumphouse #1
Sample ID: 03042660-2

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUds	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.8		03/10/26
ADONA	ND ng/L	1.8		03/10/26
9Cl-PF3ONS	ND ng/L	1.8		03/10/26
HFPO-DA (Gen-X)	ND ng/L	1.8		03/10/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.8		03/10/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.8		03/10/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.8		03/10/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.8		03/10/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.8		03/10/26
Perfluoro-n-butanoic acid(PFBA)	4.9 ng/L	3.5		03/10/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.8	10	03/10/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.8		03/10/26
Pefluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.8		03/10/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.8	10	03/10/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.8	10	03/10/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.8		03/10/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.8	10	03/10/26
Perfluorooctanesulfonate acid(PFOS)	2.0 ng/L	1.8	10	03/10/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.8	10	03/10/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.8		03/10/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.8		03/10/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.8		03/10/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 03042660

Location: Pumphouse #1 Field Blank
 Sample ID: 03042660-2 Blk

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11C1-PF3OUds	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.8		03/10/26
ADONA	ND ng/L	1.8		03/10/26
9C1-PF3ONS	ND ng/L	1.8		03/10/26
HFPO-DA (Gen-X)	ND ng/L	1.8		03/10/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.8		03/10/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.8		03/10/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.8		03/10/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.8		03/10/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.8		03/10/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	3.6		03/10/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.8	10	03/10/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.8		03/10/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.8		03/10/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.8	10	03/10/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.8	10	03/10/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.8		03/10/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.8	10	03/10/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.8	10	03/10/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.8	10	03/10/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.8		03/10/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.8		03/10/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.8		03/10/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 03042660

Location: Pumphouse #2
 Sample ID: 03042660-3

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUds	ND ng/L	1.7		03/10/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.7		03/10/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.7		03/10/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.7		03/10/26
ADONA	ND ng/L	1.7		03/10/26
9Cl-PF3ONS	ND ng/L	1.7		03/10/26
HFPO-DA (Gen-X)	ND ng/L	1.7		03/10/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.7		03/10/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.7		03/10/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.7		03/10/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.7		03/10/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.7		03/10/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.7		03/10/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.7	10	03/10/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.7		03/10/26
Pefluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.7		03/10/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.7	10	03/10/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.7	10	03/10/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.7		03/10/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.7	10	03/10/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.7	10	03/10/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.7	10	03/10/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.7		03/10/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.7		03/10/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.7		03/10/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 03042660

Location: Pumphouse #2 Field Blank
 Sample ID: 03042660-3 Blk


PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUds	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.8		03/10/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.8		03/10/26
ADONA	ND ng/L	1.8		03/10/26
9Cl-PF3ONS	ND ng/L	1.8		03/10/26
HFPO-DA (Gen-X)	ND ng/L	1.8		03/10/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.8		03/10/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.8		03/10/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.8		03/10/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.8		03/10/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.8		03/10/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.8		03/10/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.8	10	03/10/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.8		03/10/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.8		03/10/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.8	10	03/10/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.8	10	03/10/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.8		03/10/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.8	10	03/10/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.8	10	03/10/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.8	10	03/10/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.8		03/10/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.8		03/10/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.8		03/10/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

Definitions:

- MCL - Maximum Contaminant Level
- ND - Not Detected
- RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10709(A1). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
 Technical Director