

ENVIRONMENTAL LABWORKS, INC.

June 25, 2026

Mr. Larry Allen
Woodstock Wastewater Facility
45 Comeau Drive
Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on water samples from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 06/03/26.

Date/Time Collected: 06/03/26 8:35-8:44am
Collected By: Woodstock
Project ID: 06032655
Secondary ID: WD262106-08
PWS ID: 5503394

Location: Pumphouse #1, Well #1
Sample ID: 06032655-2

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533(A1)				
11Cl-PF3OUds	ND ng/L	1.7		06/05/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.7		06/05/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.7		06/05/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.7		06/05/26
ADONA	ND ng/L	1.7		06/05/26
9Cl-PF3ONS	ND ng/L	1.7		06/05/26
HFPO-DA(Gen-X)	ND ng/L	1.7		06/05/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.7		06/05/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.7		06/05/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.7		06/05/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.7		06/05/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.7		06/05/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.7		06/05/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.7	10	06/05/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.7		06/05/26
Pefluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.7		06/05/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.7	10	06/05/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.7	10	06/05/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.7		06/05/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.7	10	06/05/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.7	10	06/05/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.7	10	06/05/26
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.7		06/05/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.7		06/05/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.7		06/05/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 06032655

Location: Pumphouse #1, Well #2
Sample ID: 06032655-3

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUdS	ND ng/L	1.8		06/05/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.8		06/05/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.8		06/05/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.8		06/05/26
ADONA	ND ng/L	1.8		06/05/26
9Cl-PF3ONS	ND ng/L	1.8		06/05/26
HFPO-DA (Gen-X)	ND ng/L	1.8		06/05/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.8		06/05/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.8		06/05/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.8		06/05/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.8		06/05/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.8		06/05/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.8		06/05/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.8	10	06/05/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.8		06/05/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.8		06/05/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.8	10	06/05/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.8	10	06/05/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.8		06/05/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.8	10	06/05/26
Perfluorooctanesulfonate acid(PFOS)	3.3 ng/L	1.8	10	06/05/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.8	10	06/05/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.8		06/05/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.8		06/05/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.8		06/05/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 06032655

Location: Field Blank
Sample ID: 06032655-4 Blk


PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUdS	ND ng/L	1.9		06/05/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.9		06/05/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.9		06/05/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.9		06/05/26
ADONA	ND ng/L	1.9		06/05/26
9Cl-PF3ONS	ND ng/L	1.9		06/05/26
HFPO-DA (Gen-X)	ND ng/L	1.9		06/05/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.9		06/05/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.9		06/05/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.9		06/05/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.9		06/05/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.9		06/05/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.9		06/05/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.9	10	06/05/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.9		06/05/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.9		06/05/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.9	10	06/05/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.9	10	06/05/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.9		06/05/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.9	10	06/05/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.9	10	06/05/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.9	10	06/05/26
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.9		06/05/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.9		06/05/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.9		06/05/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

Definitions:

MCL - Maximum Contaminant Level
ND - Not Detected
RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10709(A1). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director