

ENVIRONMENTAL LABWORKS, INC.

October 7, 2026

Mr. Larry Allen
Woodstock Wastewater Facility
45 Comeau Drive
Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on water samples from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 09/16/26.

Date/Time Collected: 09/16/26 9:35-9:57am
Collected By: Woodstock
Project ID: 09162655
Secondary ID: WS263986-90
PWS ID: 5503394

Location: Pumphouse #1, Well #1
Sample ID: 09162655-2

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533(A1)				
11Cl-PF3OUds	ND ng/L	1.7		09/22/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.7		09/22/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.7		09/22/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.7		09/22/26
ADONA	ND ng/L	1.7		09/22/26
9Cl-PF3ONS	ND ng/L	1.7		09/22/26
HFPO-DA(Gen-X)	ND ng/L	1.7		09/22/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.7		09/22/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.7		09/22/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.7		09/22/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.7		09/22/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.7		09/22/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.7		09/22/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.7	10	09/22/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.7		09/22/26
Pefluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.7		09/22/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.7	10	09/22/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.7	10	09/22/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.7		09/22/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.7	10	09/22/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.7	10	09/22/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.7	10	09/22/26
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.7		09/22/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.7		09/22/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.7		09/22/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 09162655

Location: Pumphouse #1, Well #2
Sample ID: 09162655-3

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11C1-PF3OUdS	ND ng/L	1.8		09/22/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.8		09/22/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.8		09/22/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.8		09/22/26
ADONA	ND ng/L	1.8		09/22/26
9C1-PF3ONS	ND ng/L	1.8		09/22/26
HFPO-DA (Gen-X)	ND ng/L	1.8		09/22/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.8		09/22/26
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.8		09/22/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.8		09/22/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.8		09/22/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.8		09/22/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.8		09/22/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.8	10	09/22/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.8		09/22/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.8		09/22/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.8	10	09/22/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.8	10	09/22/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.8		09/22/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.8	10	09/22/26
Perfluorooctanesulfonate acid(PFOS)	3.5 ng/L	1.8	10	09/22/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.8	10	09/22/26
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.8		09/22/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.8		09/22/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.8		09/22/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 09162655

Location: Field Blank Pumphouse #1
Sample ID: 09162655-1 Blk

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (A1)				
11Cl-PF3OUdS	ND ng/L	1.9		09/22/26
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.9		09/22/26
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.9		09/22/26
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.9		09/22/26
ADONA	ND ng/L	1.9		09/22/26
9Cl-PF3ONS	ND ng/L	1.9		09/22/26
HFPO-DA (Gen-X)	ND ng/L	1.9		09/22/26
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.9		09/22/26
Perfluoro(2-ethoxyethane) sulfonic acid(PFEESA)	ND ng/L	1.9		09/22/26
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.9		09/22/26
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.9		09/22/26
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.9		09/22/26
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.9		09/22/26
Perfluorodecanoic acid(PFDA)	ND ng/L	1.9	10	09/22/26
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.9		09/22/26
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.9		09/22/26
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.9	10	09/22/26
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.9	10	09/22/26
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.9		09/22/26
Perfluorononanoic acid (PFNA)	ND ng/L	1.9	10	09/22/26
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.9	10	09/22/26
Perfluorooctanoic acid(PFOA)	ND ng/L	1.9	10	09/22/26
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.9		09/22/26
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.9		09/22/26
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.9		09/22/26
PFAS EPA 533 Hazard Index (calculation)	0.00		1	

Location: Pumphouse #1
Sample ID: 09162655-4

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 522 (P1)				
1,4-Dioxane	ND ug/L	0.020	1	09/25/26

Location: Pumphouse #2
Sample ID: 09162655-5

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 522 (P1)				
1,4-Dioxane	ND ug/L	0.020	1	09/25/26

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.


Town of Woodstock - 09162655

Definitions:

MCL - Maximum Contaminant Level
ND - Not Detected
RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratories used were ELAP #10709(A1) and #10478(P1). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



Michael F. Lupi
Laboratory Director