

ENVIRONMENTAL LABWORKS, INC.

August 9, 2024

Mr. Larry Allen
Woodstock Wastewater Facility
45 Comeau Drive
Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on a water sample from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 07/24/24.

Date/Time Collected: 07/24/24 10:00am
Collected By: Woodstock
Project ID: 07242432
Secondary ID: TW242880-81
PWS ID: 5503394

Location: Pumphouse #1 Well #1
Sample ID: 07242432-2

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 522(Y1) 1,4-Dioxane	<0.200 ug/L	0.200	1	07/30/24
EPA 533(Y2) ADONA	ND ng/L	0.954		08/05/24
9Cl-PF3ONS	ND ng/L	0.954		08/05/24
11Cl-PF3OUds	ND ng/L	0.954		08/05/24
HFPO-DA(Gen-X)	ND ng/L	0.954		08/05/24
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	0.954		08/05/24
Perfluorodecanoic acid(PFDA)	ND ng/L	0.954	10	08/05/24
Perfluorododecanoic acid(PFDoA)	ND ng/L	0.954		08/05/24
Perfluoroheptanoic acid(PFHpA)	ND ng/L	0.954	10	08/05/24
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	0.954	10	08/05/24
Perfluorohexanoic acid(PFHxA)	ND ng/L	0.954		08/05/24
Perfluorononanoic acid (PFNA)	ND ng/L	0.954	10	08/05/24
Perfluorooctanesulfonate acid(PFOS)	1.41 ng/L	0.954	10	08/05/24
Perfluorooctanoic acid(PFOA)	ND ng/L	0.954	10	08/05/24
Perfluoroundecanoic acid(PFUnA)	ND ng/L	0.954		08/05/24
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	0.954		08/05/24
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	0.954		08/05/24
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	0.954		08/05/24
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.91		08/05/24
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.91		08/05/24
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.91		08/05/24
Perfluoropentanoic acid(PFPeA)	ND ng/L	0.954		08/05/24
Perfluoro-5-oxahexanoic acid(PFMBa)	ND ng/L	0.954		08/05/24
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	0.954		08/05/24
Perfluoro-3,6-dioxahexanoic acid(NFDHA)	ND ng/L	0.954		08/05/24
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	0.954		08/05/24
PFAS EPA 533 Hazard Index (calculation)	0.00		1	08/05/24

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 07242432

Location: Pumphouse #1 Well #2

Sample ID: 07242432-3

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 522(Y1) 1,4-Dioxane	<0.200 ug/L	0.200	1	07/30/24
EPA 533(Y2) ADONA	ND ng/L	0.943		08/05/24
9Cl-PF3ONS	ND ng/L	0.943		08/05/24
11Cl-PF3OUdS	ND ng/L	0.943		08/05/24
HFPO-DA (Gen-X)	ND ng/L	0.943		08/05/24
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	0.943		08/05/24
Perfluorodecanoic acid(PFDA)	ND ng/L	0.943	10	08/05/24
Perfluorododecanoic acid(PFDoA)	ND ng/L	0.943		08/05/24
Perfluoroheptanoic acid(PFHpA)	ND ng/L	0.943	10	08/05/24
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	0.943	10	08/05/24
Perfluorohexanoic acid(PFHxA)	ND ng/L	0.943		08/05/24
Perfluorononanoic acid (PFNA)	ND ng/L	0.943	10	08/05/24
Perfluorooctanesulfonate acid(PFOS)	3.16 ng/L	0.943	10	08/05/24
Perfluorooctanoic acid(PFOA)	ND ng/L	0.943	10	08/05/24
Perfluoroundecanoic acid(PFUnA)	ND ng/L	0.943		08/05/24
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	0.943		08/05/24
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	0.943		08/05/24
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	0.943		08/05/24
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.89		08/05/24
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.89		08/05/24
Pefluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.89		08/05/24
Perfluoropentanoic acid(PFPeA)	ND ng/L	0.943		08/05/24
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	0.943		08/05/24
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	0.943		08/05/24
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	0.943		08/05/24
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	0.943		08/05/24
PFAS EPA 533 Hazard Index (calculation)	0.00		1	08/05/24

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 07242432

Location: Field Blank
Sample ID: 07242432-2 Blk


PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533(Y2)				
ADONA	ND ng/L	0.926		08/05/24
9Cl-PF3ONS	ND ng/L	0.926		08/05/24
11Cl-PF3OUds	ND ng/L	0.926		08/05/24
HFPO-DA(Gen-X)	ND ng/L	0.926		08/05/24
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	0.926		08/05/24
Perfluorodecanoic acid(PFDA)	ND ng/L	0.926	10	08/05/24
Perfluorododecanoic acid(PFDoA)	ND ng/L	0.926		08/05/24
Perfluoroheptanoic acid(PFHpA)	ND ng/L	0.926	10	08/05/24
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	0.926	10	08/05/24
Perfluorohexanoic acid(PFHxA)	ND ng/L	0.926		08/05/24
Perfluorononanoic acid (PFNA)	ND ng/L	0.926	10	08/05/24
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	0.926	10	08/05/24
Perfluorooctanoic acid(PFOA)	ND ng/L	0.926	10	08/05/24
Perfluoroundecanoic acid(PFUnA)	ND ng/L	0.926		08/05/24
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	0.926		08/05/24
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	0.926		08/05/24
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	0.926		08/05/24
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.85		08/05/24
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.85		08/05/24
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.85		08/05/24
Perfluoropentanoic acid(PFPeA)	ND ng/L	0.926		08/05/24
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	0.926		08/05/24
Perfluoro-4-oxapentanoic acid(PFMFA)	ND ng/L	0.926		08/05/24
Perfluoro-3,6-dioxahexanoic acid(NFDHA)	ND ng/L	0.926		08/05/24
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	0.926		08/05/24
PFAS EPA 533 Hazard Index (calculation)	0.00		1	08/05/24

Definitions:

MCL - Maximum Contaminant Level
RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratories used were ELAP #10854(Y1) and #12058(Y2). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director