

# ENVIRONMENTAL LABWORKS, INC.

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

March 27, 2025

Mr. Larry Allen  
Woodstock Wastewater Facility  
45 Comeau Drive  
Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on a water sample from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 03/12/25.

Date/Time Collected: 03/12/25 9:00am  
Collected By: Woodstock  
Project ID: 03122546  
Secondary ID: TW250771  
PWS ID: 5503394

**Location: Pumphouse #2 Well #5**

**Sample ID: 03122546-5**

PARAMETER	RESULTS	RL	MCL	ANALYZED
EPA 533 (Y2)				
ADONA	ND ng/L	1.85		03/18/25
9C1-PF3ONS	ND ng/L	1.85		03/18/25
11C1-PF3OUDs	ND ng/L	1.85		03/18/25
HFPO-DA (Gen-X)	ND ng/L	1.85		03/18/25
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.85		03/18/25
Perfluorodecanoic acid(PFDA)	ND ng/L	1.85	10	03/18/25
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.85		03/18/25
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.85	10	03/18/25
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.85	10	03/18/25
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.85		03/18/25
Perfluorononanoic acid (PFNA)	ND ng/L	1.85	10	03/18/25
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.85	10	03/18/25
Perfluorooctanoic acid(PFOA)	ND ng/L	1.85	10	03/18/25
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.85		03/18/25
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.85		03/18/25
Perfluoro-1-pentanesulfonate(PFPeS)	ND ng/L	1.85		03/18/25
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.85		03/18/25
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.85		03/18/25
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.85		03/18/25
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.85		03/18/25
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.85		03/18/25
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.85		03/18/25
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.85		03/18/25
Perfluoro-3,6-dioxaheptanoic acid(NFDHA)	ND ng/L	1.85		03/18/25
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.85		03/18/25
PFAS EPA 533 Hazard Index (calculation)	0.00	1		03/18/25

# **ENVIRONMENTAL LABWORKS, INC.**

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
NYSDOH #10824

---

**Town of Woodstock - 03122546**

**Definitions:**


MCL - Maximum Contaminant Level

ND - Not Detected

RL - Reporting Limit

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12058(Y2). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi  
Laboratory Director