



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

PFOA

Sample ID JH2100586
Federal Water Supply Code NY5503394 Supply Code 2302
Water Supply Town of Woodstock Water Department DOH Ulster Co Robt
Address 45 Comeau Drive Woodstock NY 12498
Sample Location Pumphouse #1
Date Collected 1/25/2021 Time Collected 9:30 AM
Sample Collector LA
Date Printed 3/19/2021

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION ng/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
Perfluorooctanoic acid	<2.00	10 ng/L	2.00	EPA 537	3/9/21	10861
Perfluorooctane Sulfonate	<2.00	10 ng/L	2.00	EPA 537	3/9/21	10861

Surrogate Recovery %

MPFHxA	67.9
M3HFPO-DA	NR
MPFDA	163
D5-N-EtFOSAA	95.8

<u>PARAMETER</u>	<u>CONCENTRATION ug/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	2/5/21	11549

Surrogate Recovery %

1,4-Dioxane-d8	88.6
----------------	------

Legend: RL = Report Limit
MCL = Maximum Contamination Level
NR - Not Reported

Comments



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE BLANK

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION ng/L</u>	<u>RL</u>	<u>METHOD</u>	Date Analyzed	Lab #
Perfluorooctanoic acid	Not Tested		EPA 537		10861
Perfluorooctane Sulfonate	Not Tested		EPA 537		10861
Surrogate Recovery %					
MPFHxA					
M3HFPO-DA					
MPFDA					
D5-N-EtFOSAA					

Comments



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

PFOA

Sample ID JH2100587
Federal Water Supply Code NY5503394 Supply Code 2302
Water Supply Town of Woodstock Water Department DOH Ulster Co Robt
Address 45 Comeau Drive Woodstock NY 12498
Sample Location Pumphouse #2
Date Collected 1/25/2021 Time Collected 9:50 AM
Sample Collector LA
Date Printed 3/19/2021

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION ng/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
Perfluorooctanoic acid	<2.00	10 ng/L	2.00	EPA 537	3/9/21	10861
Perfluorooctane Sulfonate	<2.00	10 ng/L	2.00	EPA 537	3/9/21	10861

Surrogate Recovery %

MPFHxA	65.8
M3HFPO-DA	NR
MPFDA	159
D5-N-EtFOSAA	97.8

<u>PARAMETER</u>	<u>CONCENTRATION ug/L</u>	<u>MCL</u>	<u>RL</u>	<u>METHOD</u>	<u>Date Analyzed</u>	<u>Lab #</u>
1,4-Dioxane	<0.100	1 ug/L	0.100	EPA 522	2/5/21	11549

Surrogate Recovery %

1,4-Dioxane-d8	101
----------------	-----

Legend: RL = Report Limit
MCL = Maximum Contamination Level
NR - Not Reported

Comments



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

SAMPLE BLANK

EPA 537 Perfluorinated Compounds

<u>PARAMETER</u>	<u>CONCENTRATION ng/L</u>	<u>RL</u>	<u>METHOD</u>	Date Analyzed	Lab #
Perfluorooctanoic acid	Not Tested		EPA 537		10861
Perfluorooctane Sulfonate	Not Tested		EPA 537		10861
Surrogate Recovery %					
MPFHxA					
M3HFPO-DA					
MPFDA					
D5-N-EtFOSAA					

Comments