

ENVIRONMENTAL LABWORKS, INC.

July 14, 2025

Mr. Larry Allen
 Woodstock Wastewater Facility
 45 Comeau Drive
 Woodstock, NY 12498

Dear Larry,

The following are results of the analyses performed on a water sample from the **Town of Woodstock - 2441 Route 212, Woodstock, NY** received at the laboratory on 06/26/25.

Date/Time Collected: 06/26/25 8:00am
 Collected By: Woodstock
 Project ID: 06262518
 Secondary ID: TW252384
 PWS ID: 5503394

Location: Pumphouse #2 Well #3
Sample ID: 06262518-3

PARAMETER	RESULTS	LOQ	MCL	ANALYZED
EPA 533 (Y2)				
ADONA	ND ng/L	1.94		07/08/25
9Cl-PF3ONS	ND ng/L	1.94		07/08/25
11Cl-PF3OUdS	ND ng/L	1.94		07/08/25
HFPO-DA(Gen-X)	ND ng/L	1.94		07/08/25
Perfluorobutanesulfonic acid(PFBS)	ND ng/L	1.94		07/08/25
Perfluorodecanoic acid(PFDA)	ND ng/L	1.94	10	07/08/25
Perfluorododecanoic acid(PFDoA)	ND ng/L	1.94		07/08/25
Perfluoroheptanoic acid(PFHpA)	ND ng/L	1.94	10	07/08/25
Perfluorohexanesulfonic acid(PFHxS)	ND ng/L	1.94	10	07/08/25
Perfluorohexanoic acid(PFHxA)	ND ng/L	1.94		07/08/25
Perfluorononanoic acid (PFNA)	ND ng/L	1.94	10	07/08/25
Perfluorooctanesulfonate acid(PFOS)	ND ng/L	1.94	10	07/08/25
Perfluorooctanoic acid(PFOA)	ND ng/L	1.94	10	07/08/25
Perfluoroundecanoic acid(PFUnA)	ND ng/L	1.94		07/08/25
1H,1H,2H,2H-Perfluorohexanesulfonic acid(4:2FTS)	ND ng/L	1.94		07/08/25
Perfluoro-1-pentanesulfonate (PFPeS)	ND ng/L	1.94		07/08/25
Perfluoro-n-butanoic acid(PFBA)	ND ng/L	1.94		07/08/25
1H,1H,2H,2H-Perfluorodecanesulfonic acid(8:2FTS)	ND ng/L	1.94		07/08/25
1H,1H,2H,2H-Perfluorooctanesulfonic acid(6:2FTS)	ND ng/L	1.94		07/08/25
Perfluoro-1-heptanesulfonic acid(PFHpS)	ND ng/L	1.94		07/08/25
Perfluoropentanoic acid(PFPeA)	ND ng/L	1.94		07/08/25
Perfluoro-5-oxahexanoic acid(PFMBA)	ND ng/L	1.94		07/08/25
Perfluoro-4-oxapentanoic acid(PFMPA)	ND ng/L	1.94		07/08/25
Perfluoro-3,6-dioxahexanoic acid(NFDHA)	ND ng/L	1.94		07/08/25
Perfluoro(2-ethoxyethane)sulfonic acid(PFEESA)	ND ng/L	1.94		07/08/25
PFAS EPA 533 Hazard Index (calculation)	0.00		1	07/08/25

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Town of Woodstock - 06262518

Definitions:


MCL - Maximum Contaminant Level

ND - Not Detected

LOQ - Limit of Quantitation

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #12058(Y2). The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Laboratory Director