



JH CONSULTING GROUP, INC

PO BOX 705
NEWTONVILLE, NY 12128
(518) 785-9839

LABORATORY REPORT

Sample ID JH2403222
Federal Water Supply Code NY5503394 Supply Code 2302
Water Supply Town Woodstock Water Department DOH Ulster Co Robt
Address 45 Comeau Drive Woodstock NY 12498
Sample Location Pumphouse #1
Date Collected 5/7/2024 Time Collected 7:50 AM
Sample Collector LA
Date Printed 6/19/2024

Lab ID Date Analyzed
11549 5/21/24

EPA 533 Perfluorinated and Polyfluorinated Alkyl Compounds

PARAMETER	CONCENTRATION ng/L	RL	MDL	PARAMETER	CONCENTRATION ng/L	RL	MDL	MCL
11CI-PF3OUdS	<1.86	1.86	0.930	PFBA	<1.86	1.86	0.930	
ADONA	<1.86	1.86	0.930	PFDA	<1.86	1.86	0.930	
4:2 FTS	<1.86	1.86	0.930	PFDoA	<1.86	1.86	0.930	
6:2 FTS	<1.86	1.86	0.930	PFHpS	<1.86	1.86	0.930	
8:2 FTS	<1.86	1.86	0.930	PFHpA	<1.86	1.86	0.930	
9CI-PF3ONS	<1.86	1.86	0.930	PFHxS	<1.86	1.86	0.930	
HFPO-DA	<1.86	1.86	0.930	PFHxA	<1.86	1.86	0.930	
NFDHA	<1.86	1.86	0.930	PFNA	<1.86	1.86	0.930	
PFEESA	<1.86	1.86	0.930	PFOS	2.39	1.86	0.930	10 ng/L
PFMPA	<1.86	1.86	0.930	PFOA	<1.86	1.86	0.930	10 ng/L
PFMBA	<1.86	1.86	0.930	PFPeS	<1.86	1.86	0.930	
PFBS	<1.86	1.86	0.930	PFPeA	<1.86	1.86	0.930	
				PFUnA	<1.86	1.86	0.930	

PARAMETER	CONCENTRATION ug/L	MCL	RL	METHOD	Date Analyzed	Lab #
1,4-Dioxane	Not Tested	1 ug/L	0.100	EPA 522		
Surrogate Recovery %						
1,4-Dioxane-d8						

Legend: RL = Report Limit
MCL = Maximum Contamination Level
ND - Not Detected
MDL - Method Detection Limit
J - Result is less than the RL but greater than or equal to the MDL and concentration is an approximate value.

Comments **Amended report has been issued. The PFOS was not reported correctly.**

Page 2 only applicable if a blank sample was analyzed

MCL effective as of 8/26/2020, NYS Sanitary code section 5-1.52

page 1 of 2